



Integrated Public Health Laboratory HIMS/District Hospital
Department of Microbiology/Serology
Old P.B Road Manthal, Bidar-585419

Water Testing Report

Sample ID :DPHL/467/25-26, Received Date: 03-08-2026, Reporting Date:05-08-2026

Sample : Water
Source : RO Water
Address : Gyan Ganga International School, Manthal, Bidar Di
Status : Filtered
MPN Test : Fit
Observation : No growth after 48 hours of incubation.
Comment : Fit for human consumption.




Microbiologist
Integrated Public Health Laboratory
HIMS/District Hospital
Manthal, Bidar-585419